



DEPARTMENT OF PUBLIC WORKS  
**COUNTY OF HUMBOLDT**  
 MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579  
 AREA CODE 707

ARCATA-EUREKA AIRPORT TERMINAL  
 MCKINLEYVILLE  
 FAX 839-3596

PUBLIC WORKS BUILDING  
 SECOND & L ST., EUREKA  
 FAX 445-7409

CLARK COMPLEX  
 HARRIS & H ST., EUREKA  
 FAX 445-7388

AVIATION 839-5401

ADMINISTRATION 445-7491  
 BUSINESS 445-7652  
 ENGINEERING 445-7377  
 FACILITY MAINTENANCE 445-7493

NATURAL RESOURCES 445-7741  
 NATURAL RESOURCES PLANNING 267-9540  
 PARKS 445-7651  
 ROADS & EQUIPMENT MAINTENANCE 445-7421

LAND USE 445-7205

**LAND USE DIVISION INTEROFFICE MEMORANDUM**

TO: Michelle Nielsen, Senior Planner, Planning & Building Department

FROM: Kenneth M. Freed, Assistant Engineer *KMF*

DATE: 7-2-2018

RE:

Applicant Name	Kevin Debosh
APN	522-021-010
APPS#	11491 <span style="float: right;">CUP16-264</span>

The Department has reviewed the above project and has the following comments:

- The Department's recommended conditions of approval are attached as **Exhibit "A"**.
- Additional information identified on **Exhibit "B"** is required before the Department can review the project. **Please re-refer the project to the Department when all of the requested information has been provided.**
- Additional review is required by Planning & Building staff for the items on **Exhibit "C"**. **No re-refer is required.**
- Road Evaluation Reports(s)* are required; See **Exhibit "D"**. **No re-refer is required.**

\*Note: Exhibits are attached as necessary.

Additional comments/notes:

---

---

---

---

---

---

---

---

---

---

// END //

# Exhibit "A"

## Public Works Recommended Conditions of Approval

(All checked boxes apply)

APPS # 11491

**COUNTY ROADS- FENCES & ENCROACHMENTS:**

All fences and gates shall be relocated out of the County right of way. All gates shall be setback sufficiently from the County road so that vehicles will not block traffic when staging to open/close the gate. In addition, no materials shall be stored or placed in the County right of way.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

**COUNTY ROADS- DRIVEWAY (PART 1):**

The submitted site plan is unclear and/or shows improvements that are inconsistent with County Code and/or Department of Public Works policies. The applicant is advised that these discrepancies will be addressed at the time that the applicant applies to the Department of Public Works for an Encroachment Permit. If the applicant wishes to resolve these issues prior to approval of the Planning & Building permit for this project, the applicant should contact the Department to discuss how to modify the site plan for conformance with County Code and or Department of Public Works policies. Notes:

**COUNTY ROADS- DRIVEWAY (PART 2):**

Any existing or proposed driveways that will serve as access for the proposed project that connect to a county maintained road shall be improved to current standards for a commercial driveway. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way. This also includes installing or replacing driveway culverts; minimum size is typically 18 inches.

- If the County road has a paved surface at the location of the driveway, the driveway apron shall be paved for a minimum width of 18 feet and a length of 50 feet.
- If the County road has a gravel surface at the location of the driveway, the driveway apron shall be rocked for a minimum width of 18 feet and a length of 50 feet.
- If the County road is an urban road, frontage improvements (curb, gutter, and sidewalk) shall also be constructed to the satisfaction of the Department. Any existing curb, gutter or sidewalk that is damaged shall be replaced.

The exact location and quantity of driveways shall be approved by the Department at the time the applicant applies to the Department of Public Works for an Encroachment Permit.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

**COUNTY ROADS- DRIVEWAY (PART 3):**

The existing driveway will require substantial modification in order to comply with County Code. The applicant may wish to consider relocating the driveway apron if a more suitable location is available.

**COUNTY ROADS-PARKING LOT- STORM WATER RUNOFF:**

Surfaced parking lots shall have an oil-water filtration system prior to discharge into any County maintained facility.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

**COUNTY ROADS- DRIVEWAY & PRIVATE ROAD INTERSECTION VISIBILITY:**

All driveways and private road intersections onto the County Road shall be maintained in accordance with County Code Section 341-1 (Sight Visibility Ordinance).

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

**COUNTY ROADS- PRIVATE ROAD INTERSECTION:**

Any existing or proposed non-county maintained access roads that will serve as access for the proposed project that connect to a county maintained road shall be improved to current standards for a commercial driveway. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way.

- If the County road has a paved surface at the location of the access road, the access road shall be paved for a minimum width of 20 feet and a length of 50 feet where it intersects the County road.
- If the County road has a gravel surface at the location of the access road, the access road shall be rocked for a minimum width of 20 feet and a length of 50 feet where it intersects the County road.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

**COUNTY ROADS- ROAD EVALUATION REPORT(S):**

All recommendations in the *Road Evaluation Report(s)* for County maintained road(s) shall be constructed/implemented to the satisfaction of the Public Works Department prior to commencing operations, final sign-off for a building permit, or approval for a business license. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way.

// END //