

ATTACHMENT 5

REFERRAL AGENCY COMMENTS AND RECOMMENDATIONS

The project was referred to the following referral agencies for review and comment. Those agencies that provided written comments are checked off.

Referral Agency	Response	Recommendation	Location
Building Inspection Division	✓	Approval	Attachment 5A
Division Environmental Health		No Response	
Public Works, Land Use Division	✓	Conditional Approval	Attachment 5B
CAL FIRE	✓	Denial	Attachment 5C – CALFIRE referral comments & Planning staff response to comments
Alderpoint VFC Response Area: Fire Protection District			
California Department of Fish & Wildlife		No Response	
Northwest Information Center	✓	Comments - Further Study	On file and confidential
Bear River Band of the Rohnerville Rancheria	✓	Comments	On file and confidential
Intertribal Sinkyone Wilderness Council		No Response	
Southern Humboldt Joint Unified School District		No Response	
Humboldt County Sheriff		Comments	
Humboldt County Agricultural Commissioner		No Response	
Humboldt County District Attorney		No Response	
North Coast Regional Water Quality Control Board		No Response	
State Water Resources Control Board – Division of Water Rights	✓	Approval	Attachment 5D
North Coast Unified Air Quality Management District		No Response	

ATTACHMENT 5A

Building Inspection Division Referral Response



COUNTY OF HUMBOLDT
PLANNING AND BUILDING DEPARTMENT
CURRENT PLANNING
3015 H STREET, EUREKA, CA 95501 ~ PHONE (707) 445-7245

5/3/2019

Project Referred To The Following Agencies:

AG Commissioner, Code Enforcement, County Counsel, District Attorney, Environmental Health, Sheriff, PW Land Use, Building Inspections, Alderpoint VFC:FPD, RWQCB, Southern Humboldt JUSD:School District, Cal Fish & Wildlife, CalFire, CA Division of Water Rights, Bear River Band, NWIC

Applicant Name Dobbyn Creek Pharm, LLC **Key Parcel Number** 216-317-006-000

Application (APPS#) PLN-11915-CUP Historic Planning **Assigned Planner** Keenan Hilton

Please review the above project and provide comments with any recommended conditions of approval. To help us log your response accurately, please include a copy of this form with your correspondence.

Questions concerning this project may be directed to the assigned planner for this project between 8:30am and 5:30pm Monday through Friday.

County Zoning Ordinance allows up to 15 calendar days for a response. If no response or extension request is received by the response date, processing will proceed as proposed.

If this box is checked, please return large format maps with your response.

Return Response No Later Than: 5/18/2019

Planning Commission Clerk
County of Humboldt Planning and Building Department
3015 H Street
Eureka, CA 95501
Email: PlanningClerk@co.humboldt.ca.us **Fax:** (707) 268 - 3792

We have reviewed the above application and recommend the following (please check one):

- Recommend Approval. The Department has no comment at this time.
- Recommend Conditional Approval. Suggested Conditions Attached.
- Applicant needs to submit additional information. List of items attached.
- Recommend Denial. Attach reasons for recommended denial.

Other Comments:

See presite comments & photos




DATE:


6-13-19

PRINT NAME:

Gustin Dumler

6/10/19 GD 216-317-006 11915










Future Tanks



SMA





6/10/19 GD 216-317-000 11915



ATTACHMENT 5B

Public Works, Land Use Division Referral Response



DEPARTMENT OF PUBLIC WORKS
C O U N T Y O F H U M B O L D T

MAILING ADDRESS: 1106 SECOND STREET, EUREKA, CA 95501-0579
AREA CODE 707

ARCATA-EUREKA AIRPORT TERMINAL
McKINLEYVILLE
FAX 839-3596

PUBLIC WORKS BUILDING
SECOND & L ST., EUREKA
FAX 445-7409

CLARK COMPLEX
HARRIS & H ST., EUREKA
FAX 445-7388


AVIATION 839-5401

ADMINISTRATION 445-7491
BUSINESS 445-7652
ENGINEERING 445-7377
FACILITY MAINTENANCE 445-7493

NATURAL RESOURCES 445-7741
NATURAL RESOURCES PLANNING 267-9540
PARKS 445-7651
ROADS & EQUIPMENT MAINTENANCE 445-7421

LAND USE 445-7205

LAND USE DIVISION INTEROFFICE MEMORANDUM

TO: Keenan Hilton, Planner, Planning & Building Department
FROM: Kenneth M. Freed, Assistant Engineer 
DATE: 05/06/2019

RE:	Applicant Name	DOBBYN CREEK PHARM, LLC
	APN	216-317-006
	APPS#	PLN-11915-CUP

The Department has reviewed the above project and has the following comments:

- The Department's recommended conditions of approval are attached as **Exhibit "A"**.
- Additional information identified on **Exhibit "B"** is required before the Department can review the project. **Please re-refer the project to the Department when all of the requested information has been provided.**
- Additional review is required by Planning & Building staff for the items on **Exhibit "C"**. **No re-refer is required.**
- Road Evaluation Reports(s)* are required; See **Exhibit "D"**

Note: Prior to requesting an applicant to submit a road evaluation report, verify if the project is exempt from meeting road system performance standards under CCLUO v2.0 sections 313-55.4.6.5.1 and 314-55.4.6.5.1, even if this box is checked.

No re-refer is required.

*Note: Exhibits are attached as necessary.

Additional comments/notes:

Applicant has submitted a road evaluation report, dated 8/27/2018, with Part A – Box 2 checked, certifying that the road is equivalent to a road Category 4 standard.

// END //

Exhibit "A"

Public Works Recommended Conditions of Approval

(All checked boxes apply)

AAPS # 11915

COUNTY ROADS- FENCES & ENCROACHMENTS:

All fences and gates shall be relocated out of the County right of way. All gates shall be setback sufficiently from the County road so that vehicles will not block traffic when staging to open/close the gate. In addition, no materials shall be stored or placed in the County right of way.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

COUNTY ROADS- DRIVEWAY (PART 1):

The submitted site plan is unclear and/or shows improvements that are inconsistent with County Code and/or Department of Public Works policies. The applicant is advised that these discrepancies will be addressed at the time that the applicant applies to the Department of Public Works for an Encroachment Permit. If the applicant wishes to resolve these issues prior to approval of the Planning & Building permit for this project, the applicant should contact the Department to discuss how to modify the site plan for conformance with County Code and or Department of Public Works policies. Notes:

COUNTY ROADS- DRIVEWAY (PART 2):

Any existing or proposed driveways that will serve as access for the proposed project that connect to a county maintained road shall be improved to current standards for a commercial driveway. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way. This also includes installing or replacing driveway culverts; minimum size is typically 18 inches.

- If the County road has a paved surface at the location of the driveway, the driveway apron shall be paved for a minimum width of 18 feet and a length of 50 feet.
- If the County road has a gravel surface at the location of the driveway, the driveway apron shall be rocked for a minimum width of 18 feet and a length of 50 feet.
- If the County road is an urban road, frontage improvements (curb, gutter, and sidewalk) shall also be constructed to the satisfaction of the Department. Any existing curb, gutter or sidewalk that is damaged shall be replaced.

The exact location and quantity of driveways shall be approved by the Department at the time the applicant applies to the Department of Public Works for an Encroachment Permit.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

COUNTY ROADS- DRIVEWAY (PART 3):

The existing driveway will require substantial modification in order to comply with County Code. The applicant may wish to consider relocating the driveway apron if a more suitable location is available.

COUNTY ROADS-PARKING LOT- STORM WATER RUNOFF:

Surfaced parking lots shall have an oil-water filtration system prior to discharge into any County maintained facility.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

COUNTY ROADS- DRIVEWAY & PRIVATE ROAD INTERSECTION VISIBILITY:

All driveways and private road intersections onto the County Road shall be maintained in accordance with County Code Section 341-1 (Sight Visibility Ordinance).

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

COUNTY ROADS- PRIVATE ROAD INTERSECTION: (AT COUNTY MAINTAINED RD)

Any existing or proposed non-county maintained access roads that will serve as access for the proposed project that connect to a county maintained road shall be improved to current standards for a commercial driveway. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way.

- If the County road has a paved surface at the location of the access road, the access road shall be paved for a minimum width of 20 feet and a length of 50 feet where it intersects the County road.
- If the County road has a gravel surface at the location of the access road, the access road shall be rocked for a minimum width of 20 feet and a length of 50 feet where it intersects the County road.

This condition shall be completed to the satisfaction of the Department of Public Works prior to commencing operations, final sign-off for a building permit, or Public Works approval for a business license.

COUNTY ROADS- ROAD EVALUATION REPORT(S):

All recommendations in the *Road Evaluation Report(s)* for County maintained road(s) shall be constructed/implemented to the satisfaction of the Public Works Department prior to commencing operations, final sign-off for a building permit, or approval for a business license. An encroachment permit shall be issued by the Department of Public Works prior to commencement of any work in the County maintained right of way.

// END //

ATTACHMENT 5C

CALFIRE Referral Response and Planning Staff Response to Comments

We have reviewed the above application and recommend the following (please check one):

The Department has no comment at this time.

Suggested conditions attached.

Applicant needs to submit additional information. List of Items attached.

Recommend denial.

Other comments.

Date:

Name:

Forester Comments:

Date:

Name:

Battalion Chief Comments:

Summary:

From: [Meghan Ryan](#)
To: ["Tim.Meyers@fire.ca.gov"](mailto:Tim.Meyers@fire.ca.gov)
Cc: ["Johnson, Cliff"](#); [Max C. Hilken](#)
Subject: APN: 216-371-006 - Humboldt County - APPS #11915
Date: Wednesday, January 11, 2023 9:35:00 AM
Attachments: [Attachment 5C - CAL FIRE Response.pdf](#)
[image001.jpg](#)
[11915 Site Plan 01.28.2021.pdf](#)

Good morning, Tim – I hope this email finds you well. I wanted to follow up with you regarding comments on APPS #11915, APN: 216-371-006 (comments attached). The Humboldt County WebGIS lines are approximate, so looking at GIS it appears that all cultivation was located on APN: 216-371-004, however, as approximated on the site plan, it appears that the majority of the project is located on -006. The project includes a lot line adjustment to include the southern portion of APN: 216-371-004 (see Sheet 3 of Plan set for existing and proposed parcel lines).

With that said, a review of aerial imagery from 2012 – 2021 does not show timber removal occurred. The project does not propose nor would the permit authorize any timber removal.

Please let me know if you have any additional questions or concerns regarding this project.

Best,
Meghan



Meghan Ryan
Planning Director
LACO Associates
Eureka | Ukiah | Santa Rosa | Chico
Advancing the quality of life for generations to come
707 443-5054
<http://www.lacoassociates.com>

This e-mail and its attachments are confidential. E-mail transmission cannot be assured to be secure or without error. LACO Associates therefore does not accept liability for any errors or omissions in the contents of this message. The recipient bears the responsibility for checking its accuracy against corresponding originally signed documents. If you are not the named addressee you should not disseminate, distribute, or copy this e-mail. Please notify the sender or postmaster@lacoassociates.us by e-mail if you have received this e-mail by mistake, and delete this e-mail from your system.

ATTACHMENT 5D

State Water Resources Control Board – Division of Water Rights Referral Response



COUNTY OF HUMBOLDT
PLANNING AND BUILDING DEPARTMENT
CURRENT PLANNING
3015 H STREET, EUREKA, CA 95501 ~ PHONE (707) 445-7245

5/3/2019

Project Referred To The Following Agencies:

AG Commissioner, Code Enforcement, County Counsel, District Attorney, Environmental Health, Sheriff, PW Land Use, Building Inspections, Alderpoint VFC:FPD, RWQCB, Southern Humboldt JUSD:School District, Cal Fish & Wildlife, CalFire, CA Division of Water Rights, Bear River Band, NWIC

Applicant Name Dobbyn Creek Pharm, LLC **Key Parcel Number** 216-317-006-000

Application (APPS#) PLN-11915-CUP Historic Planning **Assigned Planner** Keenan Hilton

Please review the above project and provide comments with any recommended conditions of approval. To help us log your response accurately, please include a copy of this form with your correspondence.

Questions concerning this project may be directed to the assigned planner for this project between 8:30am and 5:30pm Monday through Friday.

County Zoning Ordinance allows up to 15 calendar days for a response. If no response or extension request is received by the response date, processing will proceed as proposed.

If this box is checked, please return large format maps with your response.

Return Response No Later Than: 5/18/2019

Planning Commission Clerk
County of Humboldt Planning and Building Department
3015 H Street
Eureka, CA 95501
Email: PlanningClerk@co.humboldt.ca.us **Fax:** (707) 268 - 3792

We have reviewed the above application and recommend the following (please check one):

- Recommend Approval. The Department has no comment at this time.
- Recommend Conditional Approval. Suggested Conditions Attached.
- Applicant needs to submit additional information. List of items attached.
- Recommend Denial. Attach reasons for recommended denial.

Other Comments: This Project has an SIUR Water Right.
Registration ID: H503567 Certificate #: H100283

DATE: 5/16/19 PRINT NAME: Cheyene Keniston