

BarrierNumber	BarrierType	Status
1A	Room ID Sign - No Sign	Open
1B	Ramp Landing Slope (2.1% to 3.0%)	Open
2A	Handrail Extension - Length	Open
2B	Room ID Sign - No Sign	Open
2C	Door within Ramp Landing	Open
3	Smooth Surface at Bottom - Kickplate	Open
4	Door/Gate Landing - Slope 2.1% to 3.0%	Open
5A	Tow-Away Sign - Contact Info	Open
5B	Location - Shortest Possible Route	Open
5C	Accessible Stall Sign - Height	Open
5D	Accessible Stall Aisle - Cross-hatching	Open
6A	Room ID Sign - No Sign	Open
6B	Door Closer - Exterior Adjustment	Open
6C	Maneuvering Cl - Stored Items	Open
6D	Tactile Exit Sign - Ramp	Open
6E	Accessible Route - Spaces (Stored Items)	Open
6F	Protruding Object - Wall Mounted Object	Open
6G	Electrical Outlets - Clear Floor Space (Stored Items)	Open
6H	Fire Extinguisher - Clear Floor Space	Open
6I	Fire Extinguisher - Side Reach High (Safe Harbor)	Safe Harbor
6J	Counter - Clear Floor Space	Open
6K	Counter - Knee Clearance	Open
7A	Table - Knee Clearance	Open
7B	Operable Part - Side Reach High (Safe Harbor)	Safe Harbor
7C	Protruding Object - Wall Mounted Object	Open
7D	Room ID Sign - No Tactile Information	Open
7E	Fire Extinguisher - Side Reach High (Safe Harbor)	Safe Harbor
7F	Fire Extinguisher - Protruding Object	Open
7G	Electrical Outlets - Side Reach Low Unobstructed	Safe Harbor
7H	Clear Floor Space - Wheelchair Use (Stored Items)	Open
7I	Protruding Object	Open
7J	Tactile Exit Sign - Exit	Open
7K	Door Closer - Exterior Adjustment	Open
7L	Door Closer - Exterior Sweep	Open
7M	Room ID Sign - No Tactile Information	Open
7N	Room ID Sign - No Tactile Information	Open
7O	Tactile Exit Sign - Exit	Open
7P	Door Closer - Exterior Adjustment	Open
7Q	Door Closer - Exterior Sweep	Open
7R	Abrupt Change in Level	Open
7S	ISA Directional Sign - Non-accessible Entrance	Open
7T	Room ID Sign - No Sign	Open
8A	Room ID Sign - No Tactile Information	Open
8B	Electrical Switches - Side Reach High (Safe Harbor)	Safe Harbor
8C	Clear Floor Space - Wheelchair Use (Stored Items)	Open

8D	Table - Pedestal Base	Open
8E	Horn/Strobe - Staff Area	Open
9A	Room ID Sign - No Tactile Information	Open
9B	Operable Part - Side Reach High Unobstructed	Open
9C	Maneuvering CI - Stored Items	Open
9D	Electrical Switches - Clear Floor Space	Open
9E	Horn/Strobe - Staff Area	Open
10A	Room ID Sign - No Tactile Information	Open
10B	Maneuvering CI - Stored Items	Open
10C	Turning Space - 360 Degree Turn (<60" - Stored Items)	Open
10D	Horn/Strobe - Staff Area	Open
11A	Room ID Sign - No Sign	Open
11B	Operable Part - Side Reach High (Safe Harbor)	Safe Harbor
11C	Protruding Object - Wall Mounted Object	Open
12A	Sign - Braille/tactile Information	Open
12B	Sign - 12" Circle/triangle with Braille	Open
12C	Sign - Contrast for 12" Circle/Triangle at Unisex Restroom	Open
12D	Maneuvering CI - Latch App/Push 48"	Open
12E	Maneuvering CI - Hinge App/Pull 60"	Open
12F	Room ID Sign - No Sign	Open
12G	Dispensers - Control Point	Open
12H	Dispensers - Protruding Object	Open
12I	Toilet Paper Dispenser - Height	Open
12J	WC - Grab Bar Force	Open
13A	Sign - Braille/tactile Information	Open
13B	Sign - 12" Circle/triangle with Braille	Open
13C	Sign - Contrast for 12" Circle/Triangle at Unisex Restroom	Open
13D	Maneuvering CI - Latch App/Push 48"	Open
13E	Maneuvering CI - Stored Items	Open
13F	Room ID Sign - No Sign	Open
13G	Lavatory - Clear Floor Space	Open
13H	Lavatory - Knee Clearance	Open
13I	Lavatory - Drainpipes	Open
13J	Mirror - Bottom Edge	Open
13K	Dispensers - Control Point	Open
13L	Dispensers - Protruding Object	Open
13M	WC - Stall with Lavatory	Open
13N	WC - Rear Grab Bar Location	Open
13O	Seat Cover Dispensers - Control Point	Open
13P	WC - Grab Bar Force	Open
14A	Room ID Sign - No Sign	Open
14B	Maneuvering CI - Stored Items	Open
14C	Turning Space - 360 Degree Turn (<60" - Stored Items)	Open
14D	Tactile Exit Sign - Route	Open
14E	Room ID Sign - No Tactile Information	Open
15A	Room ID Sign - No Tactile Information	Open
15B	Maneuvering CI - Latch App/Push 44"	Open

15C	Maneuvering Cl - Stored Items	Open
15D	Clear Width - 36" Wide (Stored Items)	Open
15E	Table - Pedestal Base	Open
15F	Horn/Strobe - Staff Area	Open
16A	Room ID Sign - No Sign	Open
16B	Accessible Route - Pass Through	Open
16C	Sink - Clear Floor Space	Open
16D	Operable Part - Forward Reach Obstructed (20"-25")	Open
16E	Oven	Open
16F	Clear Floor Space - Wheelchair Use (Stored Items)	Open
16G	Shelving or Cabinets	Open
16H	Fire Extinguisher - Side Reach High (Safe Harbor)	Safe Harbor
16I	Fire Extinguisher - Protruding Object	Open
17A	Room ID Sign - No Sign	Open
17B	Maneuvering Cl - Stored Items	Open
17C	Tactile Exit Sign - Route	Open
17D	Room ID Sign - No Sign	Open
17E	Table - Knee Clearance (Stored Items)	Open
17F	Tactile Exit Sign - Exit	Open
17G	Threshold (replacement)	Open
17H	ISA Directional Sign - Non-accessible Entrance	Open
17I	Room ID Sign - No Sign	Open
17J	Handrail - Both Sides	Open
17K	Handrail Extension - Top	Open
17L	Handrail Extension - Bottom	Open
17M	Contrasting Color - Interior	Open
18A	Room ID Sign - No Tactile Information	Open
18B	Threshold (ramp required)	Open
18C	Braille - Location from Letters	Open
18D	Clothing Hook or Rod - Height	Open
18E	Operable Part - Clear Floor Space	Open
18F	Clear Floor Space - Wheelchair Use (Stored Items)	Open
18G	Room ID Sign - No Sign	Open
18H	Operable Part - Side Reach High (Safe Harbor)	Safe Harbor
18I	Protruding Object - Wall Mounted Object	Open
18J	Operable Part - Side Reach High Unobstructed	Open
19A	Sign - 12" Circle/triangle with Braille	Open
19B	Sign - Braille/tactile Information	Open
19C	Sign - Braille Distance	Open
19D	Braille - Dots Recessed	Open
19E	Dispensers - Protruding Object	Open
19F	Dispensers - Control Point	Open
19G	Dispensers - Protruding Object	Open
19H	Stall Compartment	Open
20A	Room ID Sign - No Tactile Information	Open
20B	Electrical Outlets - Side Reach Low Unobstructed	Safe Harbor
20C	Fire Extinguisher - Side Reach High (Safe Harbor)	Safe Harbor

20D	Fire Extinguisher - Protruding Object	Open
21A	Room ID Sign - No Tactile Information	Open
21B	Maneuvering CI - Hinge App/Push 44"	Open
21C	Maneuvering CI - Stored Items	Open
21D	Clear Floor Space - Wheelchair Use (Stored Items)	Open
21E	Horn/Strobe - Staff Area	Open
22A	Room ID Sign - No Tactile Information	Open
22B	Maneuvering CI - Latch App/Push 44"	Open
22C	Maneuvering CI - Stored Items	Open
22D	Clear Floor Space - Wheelchair Use (Stored Items)	Open
22E	Horn/Strobe - Staff Area	Open
23A	Room ID Sign - No Tactile Information	Open
23B	Maneuvering CI - Hinge App/Push 44"	Open
23C	Maneuvering CI - Stored Items	Open
23D	Clear Floor Space - Wheelchair Use (Stored Items)	Open
23E	Horn/Strobe - Staff Area	Open
24A	Room ID Sign - No Tactile Information	Open
24B	Maneuvering CI - Hinge App/Push 44"	Open
24C	Maneuvering CI - Stored Items	Open
24D	Horn/Strobe - Staff Area	Open
25A	Room ID Sign - No Tactile Information	Open
25B	Maneuvering CI - Hinge App/Push 44"	Open
25C	Maneuvering CI - Stored Items	Open
25D	Table - Knee Clearance	Open
25E	Clear Floor Space - Wheelchair Use (Stored Items)	Open
25F	Horn/Strobe - Meeting Room	Open

<b>OfficialResponsible</b>
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator



Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Property Owner

Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Property Owner
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Karen Clower, ADA Coordinator
Property Owner



**Notes**

Door currently is an in-swinging door, which is a violation of fire and life safety code and could result in the loss of

18 total stalls with one van accessible stall

If a person using a wheelchair was positioned at this PC station, all other stations would be blocked by the wheelc

102 Storage, 103, 104, are not for public use.

Building was last remodeled in 1995. 2010 Standards do not apply in this situation. Safe Harbor granted.







lives.

hair in position.