

January 17, 2024

RE: "Valadao" Project Mckinleyville

Initial observations of the proposed project are acceptable as presented with an addition of a Fire Hydrant located within and/or on the proposed access street. Fire hydrant coverage provided for this area are insufficient for the proposed project.

Ed Laidlaw, Fire Marshal
Arcata Fire District
Office | (707) 825-2000
prevention@arcatafire.org
www.arcatafire.org

