

State of California
Well Completion Report
 WCR Form - DWR 188 Submitted 10/10/2017
 WCR2017-004732

Owner's Well Number 1 Date Work Began 09/11/2017 Date Work Ended 09/14/2017
 Local Permit Agency Humboldt County Department of Health & Human Services - Land Use Program
 Secondary Permit Agency _____ Permit Number 15/16-0880 Permit Date 07/19/2016

Well Owner (must remain confidential pursuant to Water Code 13752)

Name Micheal Romano
 Mailing Address P.O. Box 4977
 City Arcata State CA Zip 95518

Planned Use and Activity

Activity New Well
 Planned Use Water Supply Irrigation - Agriculture

Well Location

Address 0 Stapp RD APN 317-182-019
 City Kneeland Zip 95549 County Humboldt Township 03 N
 Latitude _____ N Longitude _____ W Range 04 E
 Deg. Min. Sec. Deg. Min. Sec. Section 35
 Dec. Lat. 40.5959000 Dec. Long. -123.6973000 Baseline Meridian Humboldt
 Vertical Datum _____ Horizontal Datum WGS84 Ground Surface Elevation _____
 Location Accuracy _____ Location Determination Method _____ Elevation Accuracy _____
 Elevation Determination Method _____

Borehole Information

Orientation Vertical Specify _____
 Drilling Method Other - under-ream down-hole hammer Drilling Fluid Air
 Total Depth of Boring 260 Feet
 Total Depth of Completed Well 260 Feet

Water Level and Yield of Completed Well


Depth to first water 105 (Feet below surface)
 Depth to Static _____
 Water Level 95 (Feet) Date Measured 09/14/2017
 Estimated Yield* 15 (GPM) Test Type Air Lift
 Test Length 4 (Hours) Total Drawdown 165 (Feet)
 *May not be representative of a well's long term yield.

Geologic Log - Free Form

Depth from Surface Feet to Feet	Description
0 4	top soil
4 24	silt and brown sandstone
24 80	brown sandstone
80 195	blue basalt
195 260	black basalt

Casings


Casing #	Depth from Surface Feet to Feet	Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
1	0 60	Blank	Low Carbon Steel	Grade: ASTM A53	0.188	6			
1	60 140	Screen	Low Carbon Steel	Grade: ASTM A53	0.188	6	Milled Slots	0.05	
2	0 60	Blank	PVC	OD: 5.563 in. Thickness: 0.375 in.	0.375	5.563			
2	60 260	Screen	PVC	OD: 5.563 in. Thickness: 0.375 in.	0.375	5.563	Milled Slots	0.032	



SHOWERS (YR ROUND)
CREEK



over 100ft from proper
LINE



(SPI)


(BLM)

(SPI)

SHOWERS
PASS RD

KNEELAND RD.

BELOREVILLE



st
ed
on
th
de
ing
16

on
ss Rd.
gh
erty