

Alex Gonzalez

From: Brendan Reilly
Sent: Friday, August 1, 2025 11:53 AM
To: Alex Gonzalez
Subject: RE: RE: City of Eureka Project Referral for Jacks Seafood Security Fence

A building permit will be required to verify minimum egress requirements and accessible gate hardware as well as fire department access if applicable.

From: Alex Gonzalez <agonzalez@eurekaca.gov>
Sent: Friday, August 1, 2025 9:24 AM
Subject: RE: City of Eureka Project Referral for Jacks Seafood Security Fence

Good morning,

Attached is a referral for the Jacks Seafood Security Fence.

Please reply to this email with comments (if any) by Thursday, August 14, 2025

Also, please do not hesitate to contact me if you have any questions or need additional information.

If you are not the appropriate person, or someone else in your department/agency should instead/also receive referrals, please provide their name and e-mail address to me and we'll update the referral e-mail list.

Thank you!

Alexandra Gonzalez | Assistant Planner
Development Services - Planning
City Hall, 531 K Street, Eureka 95501
Office - (707) 441- 4211





531 K Street • Eureka, California 95501-1146
Administration: 707-441-4203
Engineering: 707-441-4194
Utility Operations: 707-441-4364

publicworks@eureka.gov • www.eureka.gov

To: Planning Department

From: Albert Figueroa, Assistant Engineer

Subject: 4 C Street (CDP-25-5)

Date: August 14th, 2025

Engineering has received and reviewed the submitted Coastal Development Permit (CDP) for 4 C Street, APN: 010-181-001. Please address the comments below and provide an updated plan that includes traffic control prior to Encroachment Permit approval.

General

1. Before beginning any work within the City right of way, including the sidewalk area, alleys, or on City property, each Contractor shall obtain an Encroachment Permit from the City Engineering Division. Certificates of Insurance and Endorsements with all required language shall be provided and approved prior to issuance of an Encroachment Permit. A City of Eureka business license is also required. There is a \$200 Encroachment Permit fee under the current fee schedule, applicable if any work is done within or from the City right of way. Encroachment Permit Fees are currently waived for sidewalk repairs.
2. Additional Public Improvements may be required if damage occurs to sidewalk, street, or other public appurtenances during construction. Any damage to public property shall be corrected by the Applicant as directed by the City.

Engineering

Construction
Development
Transportation Safety
Stormwater

Field Operations

Water Distribution
Wastewater Collection
Street Maintenance

Code Enforcement
Pretreatment
Equipment Operations

Utility Operations

Water Treatment
Wastewater Treatment