

RECEIVED

DEC 13 2017

State of California
Well Completion Report
 Form DWR 188 Submitted 12/13/2017
 WCR2017-006002

HUMBOLDT COUNTY DIVISION
 OF ENVIRONMENTAL HEALTH

Owner's Well Number 1 Date Work Began 12/12/2017 Date Work Ended 12/12/2017
 Local Permit Agency Humboldt County Department of Health & Human Services - Land Use Program
 Secondary Permit Agency _____ Permit Number 18/17-1272 Permit Date 07/05/2017

Well Owner (must remain confidential pursuant to Water Code 13752)				Planned Use and Activity	
Name				Activity	<u>Other - Modification- Installed</u>
Mailing Address				Planned Use	<u>Water Supply Irrigation - Agriculture</u>
City		State	<u>CA</u>	Zip	<u>95542</u>

Well Location					
Address			APN <u>214-233-008</u>		
City	<u>Redway</u>	Zip	<u>95560</u>	County	<u>Humboldt</u>
Latitude	<u>N</u>	Longitude	<u>W</u>	Township	<u>03 S</u>
Deg.	Min.	Sec.	Deg.	Min.	Sec.
Dec. Lat.	<u>40.1941660</u>		Dec. Long.	<u>-123.8106990</u>	
Vertical Datum			Horizontal Datum	<u>WGS84</u>	
Location Accuracy			Location Determination Method		
			Range	<u>03 E</u>	
			Section	<u>23</u>	
			Baseline Meridian	<u>Humboldt</u>	
			Ground Surface Elevation		
			Elevation Accuracy		
			Elevation Determination Method		

Borehole Information		Water Level and Yield of Completed Well	
Orientation	<u>Vertical</u>	Depth to first water	(Feet below surface)
Drilling Method	<u>Auger</u>	Depth to Static	
Drilling Fluid	<u>Air</u>	Water Level	<u>50</u> (Feet) Date Measured <u>12/12/2017</u>
Total Depth of Boring	<u>135</u> Feet	Estimated Yield*	<u>18</u> (GPM) Test Type <u>Pump</u>
Total Depth of Completed Well	<u>135</u> Feet	Test Length	<u>2</u> (Hours) Total Drawdown (feet)
		*May not be representative of a well's long term yield.	


Geologic Log - Free Form		
Depth from Surface Feet to Feet	Description	
<u>0</u> <u>135</u>	<u>Franciscan Sandstone</u>	

Casings									
Casing #	Depth from Surface Feet to Feet	Casing Type	Material	Casings Specifications	Wall Thickness (inches)	Outside Diameter (inches)	Screen Type	Slot Size if any (inches)	Description
<u>1</u>	<u>0</u> <u>135</u>	<u>Blank</u>	<u>PVC</u>	<u>OD: 5.563 in. SDR: 21 Thickness: 0.265 in.</u>	<u>0.265</u>	<u>5.563</u>			

Annular Material				
Depth from Surface Feet to Feet	Fill	Fill Type Details	Filter Pack Size	Description
<u>0</u> <u>20</u>	<u>Bentonite</u>	<u>Other Bentonite</u>		<u>Sanitary Seal</u>

Other Observations:

ENTERED
 12-14-17



RECEIVED

DEC 13 2017

PROBLET CO. DIVISION
OF ENVIRONMENTAL HEALTH

RECEIVED


JUN 8 2017

HUMBOLDT CO. DIVISION
OF ENVIRONMENTAL HEALTH



MIRANDA

PHILIPS



DIRECTIONS

GO SOUTH ON Hwy 101
TO EXIT 650. (R)
TURN / WEST 100'
ON FRENCH RD. (L)
GATE @ DEAD END
3 MILES UP RIDGE
TO HOME + WELL

PROPERTY
LINE

PROPERTY
LINE

PROPERTY
LINE

3 MILES FROM 101 HWY
PROPERTY
LINE

1 MILE
FROM SEPTIC
SITE

WELL +
SEPTIC
SITE


PROPOSE
HOUSE
+ SEPTIC

RECEIVED
MAY - 4 2018
Humboldt County
Environmental Health

RECEIVED

JUN 8 2017

HUMBOLDT CO. DIVISION
OF ENVIRONMENTAL HEALTH





Environmental Health
100 H Street, Suite 100, Eureka, CA 95501
phone: (707) 445-6215 fax: (707) 441-5699

Authorization for Access to Property

This form may be used in lieu of obtaining property owner's 'right of entry' authorization on the Water Well Application. Property owner's authorization must be received by Environmental Health prior to permit issuance.

I authorize the Department of Health and Human Services, Division of Environmental Health, access to my property for the purpose of the initial and final inspection of water well

APN 214-233-008

☒ construction

☐ destruction

☒ modification

Date 5.23.17

Property Owner's Name (print)

LOUIS PEELE

Property Owner's Signature

[Signature]