DRY WEATHER WATER PRODUCTION TEST RECOVERY DATA

Owner: Demeter Gardens, LLC **APN:** 206-331-028

Well Location latitude: 40.53707 **Longitude:** -124.05013

_____1/4	_____1/4	_____1/4	**Section:** 22	**Township:** 2N	**Range** 2E

Type of Water Measuring Equipment: Water Meter **Date Test Performed:** August 1, 2025

Company Performing Test: Fisch Drilling & Pump, Inc. **Measured By**: Matthew F., Jacob M.

TIME DATA	WATER LEVEL DATA	DISCHARGE DATA
PUMP ON Date: 8/1/25 Time: 07:00 (t_0) **PUMP OFF** Date: 8/1/25 Time: 23:00 (t_1) **DURATION OF AQUIFER TEST** Pumping: 16 hr Recovery: 3 min	**STATIC WATER LEVEL:** 24.5’ **MEASURING POINT:** Well head **HEIGHT OF MEASURING POINT ABOVE GROUND:** 23”	**HOW WAS DISCHARGE MEASURED?** Water Meter **DEPTH OF PUMP/AIRLINE:** 160’

Recovery Data:

Date	Clock Time	Time Since Pump Shutoff (min.) t_1	Recovery Water Level Measurement (ft)	Comments on Factors Affecting Test Data
8/1/25	23:00	0	27.9	
8/1/25	23:01	1	24.10	
8/1/25	23:02	2	24.7	
8/1/25	23:03	3	24.5	Recovered